

**Related Management Company, L.P.**  
410 TENTH AVENUE  
New York, NY 10001  
Office (212) 401-7656x

**Work Order No.** 2145100  
**Date Call:** 08/05/2024 06:58 PM

**Status** Work Completed

**Date Completed:** 08/07/2024 03:47 PM  
**Brief Desc:** AC not blowing cold air.

**Job Site:** 75759 [REDACTED]  
10 K Street SE  
[REDACTED]  
Washington, DC 20003

**Caller Name:** Trayon White

**Caller Phone:**  
**Occupant:** [REDACTED]

**Ok to enter?** NO  
**Category:** Heating and Cooling

**Mobile** [REDACTED]  
**SubCategory:** Air Conditioner

**Access Notes:** Has Pets: No

**Problem Description:** Resident reports that the ac is not blowing out cold air.

**Parts & Labor**

Quantity/ Hours	Item Type/ Employee Name	Description	Unit Price	Total
.0000			.00	.00
			<b>Total</b>	<b>.00</b>

**Authorized by:** \_\_\_\_\_  
**Signed by** \_\_\_\_\_  
**Dated** \_\_\_\_\_  
**Invoice No.** \_\_\_\_\_

**Full Description** Resident reports that the ac is not blowing out cold air.; Has Pets: No

**Technician Notes:** flashing red needs charge; Replaced Unit size 21 new

**Related Management Company, L.P.**  
410 TENTH AVENUE  
New York, NY 10001  
Office (212) 401-7656x

**Work Order No.** 1925235  
**Date Call:** 07/31/2023 12:54 PM

**Status** Work Completed

**Date Completed:** 08/01/2023 06:35 AM  
**Brief Desc:** :)

**Job Site:** 75759/ [REDACTED]  
10 K Street SE  
[REDACTED]  
Washington, DC 20003

**Caller Name:** Trayon White

**Caller Phone:**  
**Occupant:** [REDACTED]

**Ok to enter?** YES  
**Category:** Heating and Cooling

**Mobile** [REDACTED]  
**SubCategory:** Air Conditioner

**Access Notes:** after 10a; Has Pets: No

**Problem Description:** AC is blowing hot air.

**Parts & Labor**

Quantity/ Hours	Item Type/ Employee Name	Description	Unit Price	Total
.0000			.00	.00
			<b>Total</b>	<b>.00</b>

**Authorized by:** \_\_\_\_\_  
**Signed by** \_\_\_\_\_  
**Dated** \_\_\_\_\_  
**Invoice No.** \_\_\_\_\_

**Full Description** AC is blowing hot air.; Has Pets: No

**Technician Notes:** Reset unit, flashing red, dirty filter was replaced.